

**VILLAGE OF WATERLOO  
RESOLUTION NO. 01-12-16-02**

**WHEREAS**, the State of Nebraska Department of Health and Human Services requires the Village of Waterloo provide a procedure to be used when selecting sample sites for total coliform repeat monitoring.


**NOW THEREFORE, BE IT RESOLVED BY THE BOARD OF TRUSTEES OF THE VILLAGE OF WATERLOO, NEBRASKA, AS FOLLOWS:**

**THAT**, the Total Coliform Repeat Monitoring Sample Site Selection, attached hereto, are hereby approved and shall go into effect immediately.

PASSED THIS 12 DAY OF January, 2016

ATTEST:

Melissa Johnson  
Melissa Johnson  
Village Clerk




Village of Waterloo


Ken Hitchler  
Ken Hitchler  
Chairperson

## Total Coliform Repeat Monitoring Sample Site Selection

The Village of Waterloo will use the following procedure when selecting sample sites to be used for Total Coliform Repeat Monitoring.

1. Preference will be given to a site that is located within Five service connections on either side (Up & Down) of the location of the Coliform positive sample (Original).
2. If a site is not suitable within five connections up and/or down from original site location, a site will be selected from a location that is as near as possible to the original location that is representative of that area of the distribution system.
3. All repeat sites selected will be evaluated to ensure that they meet the systems criteria of a representative site. That is, the site meets the same physical/environmental conditions of the routine sample sites of the system.
4. If needed, the same repeat sites may/will be used again, if future testing is required for the respective original site.

  
\_\_\_\_\_  
Mayor/Chairperson

  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Water System Representative

  
\_\_\_\_\_  
Date